Certificate of Compliance

Certificate Number 20080529-E231911C
Report Reference E231911, 2005 January 24

Issue Date 2008 May 29



Issued to: PR ELECTRONICS A/S

LERBAKKEN 10

8410 ROENDE DENMARK

This is to certify that representative samples of

AUXILIARY DEVICES

Auxiliary Devices Open Type Transmitters, Cat. No. 5116A and 5116B.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 508 - Industrial Control Equipment

CSA-C22.2 No. 14 - Industrial Control Equipment

Additional Information: See Addendum for Electrical Ratings.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers: the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: **Louise Jakobsen, Project Engineer**Underwriters Laboratories Inc.

Reviewed by: **Peter F. Joyes, Project Engineer** Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20080529-E231911C**Report Reference **E231911, 2005 January 24**

Issue Date 2008 May 29



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Electrical Ratings:

Cat. No.	Supply Voltage	Max Load	Input	Output	Relay
5116A	24-230 VAC	3 W	0-100 mA,	0-20 mA,	2 A/250 VAC, resistive
5116B	or 24-250		0-250 VDC	0-10 V	
	VDC				