



The manufacturer may use the mark:



Revision 3.0 August 01, 2024
Surveillance Audit Due
August 01, 2027



Certificate / Certificat Zertifikat / 合格証

PREI 070902 P0002 C01.5

exida hereby confirms that the:

Pulse Isolator 9202
Product Version 9202-003

PR electronics A/S
Rønede - Denmark

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-3

and meets requirements providing a level of integrity to:

Systematic Capability: SC 2 (SIL 2 Capable)

Random Capability: Type B Route 2_H Device
PFH/PFD_{avg} and Architecture Constraints
must be verified for each application

Safety Function:

The 9202 – Pulse Isolator provides EX-isolation of digital signals, on/off converter for NAMUR sensors or mechanical switches, between hazardous areas and safe areas. .

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.




Evaluating Assessor


Certifying Assessor

9202 Pulse Isolator

Product Version 9202-003

Systematic Capability: SC 2 (SIL 2 Capable)**Random Capability: Type B Route 2_H Device****PFH/PFD_{avg} and Architecture Constraints
must be verified for each application****9202 Pulse Isolator****Systematic Capability :**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

9202 Configurations

| | λ_s | λ_{DD} | λ_{DU} |
|--------------|-------------|----------------|----------------|
| Relay Output | 108 | 85 | 55 |
| Opto Output | 112 | 85 | 46 |

IEC 61508 Failure Rates in FIT*

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: PR 23/12-098 R035 V1R0

Safety Manual: 9202 Safety Manual V7R3

