




Segurança


DEKRA Compulsório INMETRO




	DK	UK	FR	DE
A	Indgangssignaler	Input signals	Signaux d'entrée	Eingangssignale
B	Udgangssignaler	Output signals	Signaux de sortie	Ausgangssignale
C	NAMUR	NAMUR	NAMUR	NAMUR
D	Mekanisk kontakt	Mechanical switch	Commutateur mécanique	Mechanischer Schalter
E	Relæ	Relay	Relais	Relais
F	Forsyning -	Supply -	Alimentation -	Versorgung -
G	Forsyning +19,2...31,2 VDC	Power supply +19,2...31,2 VDC	Alimentation +19,2...31,2 Vcc	Versorgung +19,2...31,2 VDC
H	Modulstatus	Device status	Etat du module	Gerätestatus
I	Forsyning via power rail	Power supply via power rail	Alimentation par rail	Versorgung über Power Rail
Ch.1	Kanal 1	Channel 1	Voie 1	Kanal 1
Ch.2	Kanal 2	Channel 2	Voie 2	Kanal 2
N.C.	Normalt lukket	Normally closed	Normalement fermé	Öffner
N.O.	Normalt åben	Normally open	Normalement ouvert	Schließer



DK Pásætning af PR45xx:
1: Indsæt tappene på 45xx i hullerne øverst på modulet.
2: Sving 45xx på plads.
Aftagning af 45xx:
3/4: Tryk på udlosserknap i bunden af 45xx og sving 45xx op.




UK Mounting of PR45xx:
1: Insert the tabs of the PR 45xx into the holes at the top of the device.
2: Hinge the PR 45xx down until it snaps into place.



Demounting of the PR 45xx:
3: Push the release button on the bottom of the PR 45xx and hinge the PR 45xx out and up.
4: With the PR 45xx hinged up, remove from holes at the top of the device.

FR Montage du PR45xx:
1: Insérez les crochets du 45xx dans les trous en haut du module.
2: Poussez le bas du 45xx vers le module.
Démontage du 45xx:
3/4: Appuyez sur le bouton de déclenchement en dessous du 45xx, puis tirez le 45xx vers le haut.




DK Frigørelse fra power rail / DIN-skinne
Husk først at demontere tilslutningsklemmerne med farlig spænding. Modulet frigøres fra skinnen ved at løfte i den nederste lås.

UK Demounting from power rail / DIN rail
First, remember to demount the connectors with hazardous voltages. Detach the device from the rail by lifting the bottom lock.

FR Démontage du rail d'alimentation / rail DIN
Tout d'abord, n'oubliez pas de démonter les connecteurs où règnent des tensions dangereuses. Débloquez le verrou inférieur pour dégager le module du rail.

DE Lösen von Power Rail / DIN-Schiene
Zunächst ist gefährliche Spannung von den Anschlussklemmen zu trennen. Das Gerät wird von der Schiene gelöst, indem man den unteren Verschluss löst.



DK Sideskilt
UK Side label
FR Etiquette
DE Typenschild

Produktionsår fremgår af de første cifre i serienummeret.
Års af produktionne kan fås fra de første to cifre i serienummeret.
L'année de production est définie grâce aux deux premiers chiffres du numéro de série.
Die ersten beiden Ziffern der Seriennummer geben das Produktionsjahr an.



DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

9202Bxxx		9202Axxx	
IECEx	[Ex ia Ga] IIC/IIB/IIA Ex nA nC IIC T4 Gc [Ex ia Da] IIIC [Ex ia Ma] I	IECEx KEM 06.0039X Installation Drawing: 9202QI01	Ex nA nC IIC T4 Gc IECEx KEM 06.0039X Installation Drawing: 9202QI01
ATEX	II (1) G [Ex ia Ga] IIC/IIB/IIA II 3G Ex nA nC IIC T4 Gc II (1) D [Ex ia Da] IIIC [Ex ia Ma] IIIC	KEMA 07ATEX 0146 X Installation Drawing: 9202QA01	II 3 G Ex nA nC IIC T4 Gc KEMA 07ATEX 0146 X Installation Drawing: 9202QA01
FM	Install in CL 1, Div. 2, Gr. A-D T4 Provides IS output to CL-I-III Div. I/2, Gr. A-G or CL 1, Zn2 AExEx nA nC IIC [ia] IIC T4	FM16US0055X / FM16CA0028X Installation Drawing: 9202QF01	Install in CL 1, Div. 2, Gr. A-D T4 or CL 1, Zone 2, AExEx nA nC IIC T4
INMETRO	[Ex ia Ga] IIC/IIB/IIA [Ex ia Da] IIIC [Ex ia Ma] I Ex nA nC IIC T4 Gc	DEKRA 16.0005 X Installation Drawing: 9202QB01	
UL	Install in CL 1 DIV 2 GP A-D T4 provides IS circuits to CL I-III DIV 1 GP A-G or install in CL 1 Zn2 Gp T4 provides IS circuits to CL 1 Zn2 Gp IIC/Zn2 Gp IIIC	E233311 Installation Drawing: 9202QU01	Install in CL 1, Div. 2, Gr. A-D T4 or CL 1, Zone 2, AExEx nA nC IIC T4

DK Kina RoHS **UK** China RoHS **FR** RoHS chinois **DE** China-RoHS

Part Name	Hazardous Substances					
	Lead (Pb)	Mercury (Hg)	Cadmium (Cd)	Hexavalent Chromium (Cr VI)	Polybrominated biphenyls (PBB)	Polybrominated diphenyl ethers (PBDE)
Printed circuit board	X	0	0	0	0	0

This table is prepared in accordance with the provisions of SJ/T 11364
0: Indicates that said hazardous substance contained in all of the homogeneous materials for this part is below the limit requirement of GB/T 26572.

X: Indicates that said hazardous substance contained in at least one of the homogeneous materials used for this part is above the limit requirement of GB/T 26572.

The product's Environmentally Friendly Use Period (EFUP) is 50 years

DK Dokumentation, godkendelser og yderligere information findes på internettet på www.prelectronics.dk

UK Documentation, permits and other information can be found on the internet at www.prelectronics.com

FR La documentation et toute autre information peuvent être trouvées sur l'Internet sur notre site: www.prelectronics.fr

DE Dokumentation, Zulassungen und andere Informationen können auf unserer Internet-Seite unter www.prelectronics.de gefunden und abgerufen werden.

BR Documentações, licenças e outras informações podem ser encontradas no site www.prelectronics.com

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK Ex-godkendelser **UK** I.S approvals **FR** Approbations S.I. **DE** Ex-Zulassungen

DK

ATEX Installation drawing 9202QA01-V5R0

For safe installation of 9202 the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

Year of manufacture can be taken from the first two digits in the serial number.

For installation in Zone 2 / Division 2 the following must be observed.

The 4501 programming module is to be used solely with PR electronics modules. It is important that the module is undamaged and has not been altered or modified in any way. Only 4501 modules free of dust and moisture shall be installed.

ATEX Certificate KEMA 07ATEX0146 X

Marking 9202Bxx II (1) G Ex nA IIC IIC/IIIA

I (1) 3G Ex nA nC IIC T4 Gc

I (1) D Ex nA IIC

I (M1) [Ex ia Ma]

Marking 9202Axx II 3G Ex nA nC IIC T4 Gc

Standards EN 60079-0 : 2012, EN 60079-11 : 2012, EN 60079-15 : 2010

Supply terminal (31,32)

Voltage : 19.2 – 31.2 VDC

Status Relay, terminal (33,34)

Voltage max: 125 VAC / 110 VDC

Power max: 62.5 VA / 32 W

Current max: 0.5 AAC / 0.3 ADC

Installation notes:

Install in pollution degree 2, overvoltage category II as defined in EN 60066-1

Do not separate connectors when energized and an explosive gas mixture is present.

Do not mount or remove modules from the Power Rail when an explosive gas mixture is present.

Disconnect power before servicing.

The wiring of unused terminals is not allowed.

In type of protection [Ex ia] the parameters for intrinsic safety for gas group IIB are applicable.

For installation in Zone 2, the module shall be installed in an enclosure in type of protection Ex n or Ex e, providing a degree of protection of at least IP54. Cable entry devices and blanking elements shall fulfill the same requirements.

For installation on Power Rail in Zone 2, only Power Rail type 9400 supplied by Power Control Unit type 9410 (Type Examination Certificate KEMA 07ATEX0152 X) is allowed.

For installation on Power Rail in Zone 2, only Power Rail type 9400 supplied by Power Control Unit type 9410 (Type Examination Certificate KEMA 07ATEX0152 X) is allowed.

IECEx Installation drawing 9202QI01-V5R0

For safe installation of 9202 the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

Year of manufacture can be taken from the first two digits in the serial number.

For installation in Zone 2 / Division 2 the following must be observed.

The 4501 programming module is to be used solely with PR electronics modules. It is important that the module is undamaged and has not been altered or modified in any way. Only 4501 modules free of dust and moisture shall be installed.

IECEx Certificate KEM 06.039 X

Marking 9202Bxx [Ex ia Ga] IIC/IIIA

Ex nA nC IIC T4 Gc

[Ex ia Da] IIC

[Ex ia Ma]

Marking 9202Axx Ex nA nC IIC T4 Gc

Standards IEC60079-15 : 2005, IEC60079-11:2011, IEC60079-0 : 2011

Supply terminal (31,32)

Voltage: 19.2 – 31.2 VDC

Status Relay, terminal (33,34)

Voltage max: 125 VAC / 110 VDC

Power max: 62.5 VA / 32 W

Current max: 0.5 AAC / 0.3 ADC

Installation notes:

Install in pollution degree 2, overvoltage category II as defined in IEC60066-1

Do not separate connectors when energized and an explosive gas mixture is present.

Do not mount or remove modules from the Power Rail when an explosive gas mixture is present.

Disconnect power before servicing.

The wiring of unused terminals is not allowed.

In type of protection [Ex ia] the parameters for intrinsic safety for gas group IIB are applicable.

For installation in Zone 2, the module shall be installed in an enclosure in type of protection Ex n or Ex e, providing a degree of protection of at least IP54. Cable entry devices and blanking elements shall fulfill the same requirements.

For installation on Power Rail in Zone 2, only Power Rail type 9400 supplied by Power Control Unit type 9410 (Type Examination Certificate KEMA 07ATEX0152 X) is allowed.

For installation on Power Rail in Zone 2, only Power Rail type 9400 supplied by Power Control Unit type 9410 (Type Examination Certificate KEMA 07ATEX0152 X) is allowed.

FM Installation drawing 9202QF01-V5R0

For safe installation of 9202B the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

For installation in Zone 2 / Division 2 the following must be observed.

The 4501 programming module is to be used solely with PR electronics modules. It is important that the module is undamaged and has not been altered or modified in any way. Only 4501 modules free of dust and moisture shall be installed.

Hazardous Classified Location

Class III/III, Division 1, Group A,B,C,D,E,F,G or Class I, Zone 0/1 Group IC, [AEx ia] IIC or Group IC, [Ex ia] IIC Gc

Unclassified Location or Hazardous Classified Location

Class I, Division 2, Group A,B,C,D T4 or Class I, Zone 2 Group IIC T4 Gc

Simple Apparatus or Intrinsically safe apparatus with entity parameters:

(U) ≥ VI (Uo)

Imax < 10 mA

Pi < PIPmax

Ca(Co) ≥ Caste + Cl

La(Lo) ≥ Lable + Li

Uo / VT: 10.6 V

Io / Isc: 12 mA

Po / Pm: 32 mW

Lo/Ro La/Ra: 1150 μH/Q

Group IIC 2.0 μF 6.0 μF 18 μF

Ca/Cs 260 mH 780 mH 1000 mH

Supply / Output (terminal 31,32,33,34) (terminal 91,92,93,94,95)

Terminal CH1(44,42) CH2(54,52)

UL Installation drawing – V1R0

For safe installation of the Process Control Equipment (Associated Apparatus) 9202 the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards that apply to this area.

For installation in DIV2/Zone 2 the following must be observed.

The 4501 programming module is to be used solely with PR electronics modules. It is important that the module is undamaged and has not been altered or modified in any way. Only 4501 modules free of dust and moisture shall be installed.

9202A1-U9 and 9202B1-U9: One channel Opto output

9202A1-B9 and 9202B1-B9: One channel Opto output

9202A2-U9 and 9202B2-U9: One channel N.O. Relay output

9202A2-B9 and 9202B2-B9: Two channel N.O. Relay output

9202A3-U9 and 9202B3-U9: One channel N.C. Relay output

9202A3-B9 and 9202B3-B9: Two channel N.C. Relay output

Marking: Proc. Cont. Eq. for Use in Haz. Loc.

Install in CL1 DIV2 GP A-D T4

or CL1 2n2 Gp IIC T4 provides IS

E233311 circuits for CL1 Zn0 Gp IIC/Zn20 Gp IIC

Um=253V [Ex ia] Installation Drawing: 9202QU01

Proc. Cont. Eq. for Use in Haz. Loc.

Install in CL1 DIV2 GP A-D T4

or CL1 2n2 Gp IIC T4

E233311 Installation Drawing: 9202QU01

Standards: IEC 60079-0 : 2012, IEC 60079-11 : 2012, IEC 60079-15 : 2010

UL12101 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS Edition 9 - Revision Date 2018/03/01

CSA C22.2 NO. 213 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS- Edition 3 - Issue Date 2017/09/01

UL1913 STANDARD FOR INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS- Edition 8 - Revision Date 2015/10/01

CSA C22.2 NO. 60079-0 EXPLOSIVE ATMOSPHERES — PART 0: EQUIPMENT — GENERAL REQUIREMENTS- Edition 3 - Issue Date 2015/01/01

CSA C22.2 NO. 60079-11 EXPLOSIVE ATMOSPHERES — PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY- Edition 2 - Issue Date 2014/02/01

The 9202Axx equipment is intended for installation in non-hazardous locations or Class I, Division 2, Groups A – D or Zone 2, Groups B – C.

The 9202Bxx equipment is intended for installation in non-hazardous locations or Class I, Division 2, Groups A – D or Zone 2, Groups B – C.

The Ex output current of this associated apparatus is limited by a resistor such that the output voltage-current point is a straight line drawn between open-circuit voltage and short-circuit current.

Selected intrinsically safe equipment must be third party listed as intrinsically safe for the application, and have intrinsically safe entity parameters conforming with Table 1 below.

TABLE 1: Associated Equipment

Max. Current (I) z Max. Voltage (V) or (U) z Isc or I (or Ito)

P max. Pi z Po

Ci + Cable s Ca (or Co)

Li + Cable s La (or Lo)

The module may also be connected to a simple apparatus as defined in Article 504.2 and installed and temperature classified in accordance with Article 504.10(D) of the National Electrical Code (ANSI/NFPA 70), or the Canadian Electrical Code (C22.1).

Capacitance and inductance of the field wiring from the intrinsically safe equipment to the associated apparatus shall be calculated and must be included in the system calculations as shown in Table 1. Cable capacitance, Cabc, plus intrinsically safe equipment capacitance, Ci must be less than the marked capacitance, Cabc (or Co), shown on any associated apparatus used. The same applies for inductance (Labc). Labc and/or its reciprocal, Wabc, plus cable capacitance, Cabc, plus inductance per foot are not known, the following values shall be used: Cabc = 60 pF/ft, Labc = 0.2 μH/ft.

Where multiple circuits extend from the same piece of associated apparatus, they must be installed in separate cables or in one cable having suitable insulation. Refer to Article 504.3(B) of the National Electrical Code (ANSI/NFPA 70) or the Canadian Electrical Code (C22.1).

Inductively safe circuits must be wired and separated in accordance with Article 504.20 of the National Electrical Code (ANSI/NFPA 70) or other local codes, as applicable.

The modules has not been evaluated for use in combination with another associated apparatus.

For installations in which both the Ci and Li of the intrinsically safe apparatus exceeds 1% of the Ca (or Co) and La (or Lo) parameters of the associated apparatus (excluding the cable), then 50% of Ca (or Co) and La (or Lo) parameters are applicable and shall not be exceeded. The reduced capacitance shall not be greater than 1 μF for Groups A and D, and 600 nF for Groups B and C. The values of Ca (or Co) and La (or Lo) determined by this method shall be exceeded by the sum of all of Ci plus cable capacitances and the sum of all of Li plus cable inductances in the circuit respectively.

For installations in which both the Ci and Li of the intrinsically safe apparatus exceeds 1% of the Ca (or Co) and La (or Lo) parameters of the associated apparatus (excluding the cable), then 50% of Ca (or Co) and La (or Lo) parameters are applicable and shall not be exceeded. The reduced capacitance shall not be greater than 1 μF for Groups A and D, and 600 nF for Groups B and C. The values of Ca (or Co) and La (or Lo) determined by this method shall be exceeded by the sum of all of Ci plus cable capacitances and the sum of all of Li plus cable inductances in the circuit respectively.

For installations in which both the Ci and Li of the intrinsically safe apparatus exceeds 1% of the Ca (or Co) and La (or Lo) parameters of the associated apparatus (excluding the cable), then 50% of Ca (or Co) and La (or Lo) parameters are applicable and shall not be exceeded. The reduced capacitance shall not be greater than 1 μF for Groups A and D, and 600 nF for Groups B and C. The values of Ca (or Co) and La (or Lo) determined by this method shall be exceeded by the sum of all of Ci plus cable capacitances and the sum of all of Li plus cable inductances in the circuit respectively.

For installations in which both the Ci and Li of the intrinsically safe apparatus exceeds 1% of the Ca (or Co) and La (or Lo) parameters of the associated apparatus (excluding the cable), then 50% of Ca (or Co) and La (or Lo) parameters are applicable and shall not be exceeded. The reduced capacitance shall not be greater than 1 μF for Groups A and D, and 600 nF for Groups B and C. The values of Ca (or Co) and La (or Lo) determined by this method shall be exceeded by the sum of all of Ci plus cable capacitances and the sum of all of Li plus cable inductances in the circuit respectively.

For installations in which both the Ci and Li of the intrinsically safe apparatus exceeds 1% of the Ca (or Co) and La (or Lo) parameters of the associated apparatus (excluding the cable), then 50% of Ca (or Co) and La (or Lo) parameters are applicable and shall not be exceeded. The reduced capacitance shall not be greater than 1 μF for Groups A and D, and 600 nF for Groups B and C. The values of Ca (or Co) and La (or Lo) determined by this method shall be exceeded by the sum of all of Ci plus cable capacitances and the sum of all of Li plus cable inductances in the circuit respectively.

For installations in which both the Ci and Li of the intrinsically safe apparatus exceeds 1% of the Ca (or Co) and La (or Lo) parameters of the associated apparatus (excluding the cable), then 50% of Ca (or Co) and La (or Lo) parameters are applicable and shall not be exceeded. The reduced